

APPENDIX B

California Upset Rules and Data

California is divided into 35 local air districts, which each have their own air pollution control rules. Details regarding the upset reporting and variance requirements for the South Coast Air Quality Management District (SCAQMD) and the Bay Area Air Quality Management District (BAAQMD) are discussed below. In addition to the problems with certain California rules discussed below, a recent report by the Environmental Working Group found lax enforcement by California's air pollution control districts and average penalties that are too low to deter noncompliance.¹

Bay Area Air Quality Management District

Upset Rules: The Bay Area Air Quality Management District's SIP approved upset rules appear to be consistent with the Clean Air Act and EPA's guidance. BAAQMD does, however, grant state variances. While these variances are not approved into the SIP, they can be used to exempt upset emissions from state enforcement.

- **Breakdown rules:** BAAQMD's SIP approved rules recognize the district's enforcement discretion with respect to excess emissions resulting from "breakdowns."² A breakdown is defined as an "unforeseeable failure or malfunction of any air pollution control equipment or operating equipment which causes a violation of any emission standard or limitation."³ Breakdowns do not include incidents resulting from "intent, neglect, or disregard" of the law or improper maintenance, or incidents that cause a nuisance or are an "excessively recurrent" breakdown of the same equip-

ment.⁴ The breakdown rule provides that BAAQMD "may refrain from" taking enforcement action for violations of emission standards resulting from a breakdown provided the emissions do not interfere with attainment or maintenance of the federal national ambient air quality standards.⁵ Only emissions occurring within 24 hours of the breakdown qualify under the breakdown provision.⁶

- **Variance Rules:** For breakdown emissions lasting longer than 24 hours, or for excess emissions caused by other factors, facilities can apply to the BAAQMD Hearing Board for a variance.⁷ If a variance is granted, it temporarily relieves the source from the obligation of complying with a district regulation or permit condition. BAAQMD's variance provisions are not included in the SIP, and cannot immunize emissions that exceed federal air pollution limits from EPA or citizen enforcement. Despite this, BAAQMD's granting of variances appears to

Henry Clark, Richmond, CA

I live on the front line of the chemical assault from the Chevron-Texaco Refinery in Richmond, California. The daily toxic emissions that my community is bombarded with are dangerous and deadly, the dioxins, benzene and xylene emissions. When there is an upset or explosion we have been exposed to toxics emissions for over a week. There is a high rate of childhood asthma and cancer in the Richmond, CA, area. This situation must stop! Chevron-Texaco must be held accountable to operate safely and compensate the community for years and years of chemical assaults.

violate the Clean Air Act requirement that states enforce emission standards at least as stringent as those in the SIP.⁸ BAAQMD's variance procedures and the state statute authorizing them should, therefore, be revised to provide that the process is simply an exercise of the agency's enforcement discretion and that all exceedances of emission limits are violations of the law subject to enforcement.

Reporting: BAAQMD does not have a general rule that requires facilities to report excess emissions. Its breakdown and variance reports should identify some of these emissions. In addition, BAAQMD's new flare monitoring rules and pressure relief device rules require the reporting of all emissions, routine and upset, from certain types of equipment.

- *Breakdown Reports:* Sources seeking breakdown relief must notify BAAQMD "immediately" following a breakdown.⁹ The notification must include the location, equipment involved and, to the extent known, the cause of the breakdown. A written follow-up report must be filed within 30 days that includes sufficient information for the agency to determine whether the cause of the emissions was truly a breakdown, a summary of corrective action taken and a summary of actions taken to ensure such breakdowns will not occur in the future.¹⁰ The rules do not require the reports to identify the type and quantity of emissions released, although agency guidance does.
- *Variance Files:* Applications to the Hearing Board for variances must include "to the extent possible" the number and type of emission points and measurements or estimates of the quantity and nature of emissions released during the event for which a variance is sought, as well as the quality in excess of legal limits.¹¹
- *Flare Monitoring Reports:* BAAQMD's flare monitoring rule requires monthly reports which specify the methane, non-methane and sulfur dioxide emissions, both upset and routine, from flares.¹²
- *Pressure Relief Device Reports:* BAAQMD's pressure relief device rules apply to refineries and chemical plants and require reporting of all releases greater than 10 pounds from pressure relief devices.¹³ These reports must include the amount of total organic compounds, ammonia, hydrogen sulfide, chlorine, sulfur dioxide, sulfur trioxide, hydrofluoric acid, and difluoroethane released.

While these reports each provide some information about certain types of upset emissions, without a centralized reporting system for all excess emissions that includes specific estimates of quantities, it was extremely difficult to determine how much excess pollution the facilities studied were emitting.

BAAQMD staff informed us that episode reports were the best place to look for upset emission data. Episode Printouts summarize all of the reported excess emission events at a particular facility. Individual Episode Reports include such useful information at the date and time of the event, the units involved, and whether a Notice of Violation was issued, but often fail to include the amount of pollution emitted during an event. Instead, the reports frequently simply site the regulatory limit and indicate that the facility exceeded that limit.

A further problem with the BAAQMD's system was the number of episode reports that were lost, on corrupted electronic media, or withheld by the legal department pending settlement.

BAAQMD would not produce information within numerous reports that were "withheld by legal." The emission data within the withheld documents is clearly public information under the Clean Air

Company	Reports Lost	Reports Withheld by Legal	Reports Corrupted
Shell Oil Refinery		17	
Tesoro Oil Refinery	8	11	1
Valero Oil Refinery		28	6

Act and should not be withheld for any length of time.¹⁴ Further, the emissions reports requested were from 2001 and 2002. It is unreasonable for the District to withhold even the non-emission information in these reports for this extended period of time.¹⁵

The District does post incident reports that it deems of significant interest to the public on its website.¹⁶ A limited number of reports are posted, however, and the reports often do not include information regarding the type or amount of pollution emitted. The reports do, though, include helpful information such as the number of complaints received during the event and the actions taken in response by BAAQMD.

Data: The attached spreadsheets include upsets documented in BAAQMD's episode report database for the following facilities:

Facility Name	Facility Location
Tesoro	Martinez, CA
Valero	Benicia, CA
Shell	Martinez, CA

Because BAAQMD does not have a uniform system for reporting quantities of excess emissions, and because so many of the reports were missing entirely or lacking emission data, it was impossible to determine how much pollution the facilities studied emitted during upsets. As can be seen from the attached Tesoro, Valero and Shell spreadsheets, the facilities frequently reported “break-

downs” but did not indicate the total amount of pollution released during the upset.¹⁷ Due to this lack of data, we did not attempt to total these facilities’ upset emissions.

Our findings regarding the causes of upsets at Texas and Louisiana facilities, however, are consistent with a report by Communities for a Better Environment that found repeated Bay Area refinery flaring due to routine and preventable conditions, including equipment breakdowns, power failures and lack of compressor capacity.¹⁸

South Coast Air Quality Management District

Upset Rules: The South Coast Air Quality Management District’s SIP includes upset provisions that violate the Clean Air Act and EPA guidance. SCAQMD’s breakdown rules exempt certain upset emissions from compliance with emission limits and have not been approved into the SIP. SCAQMD’s variance rule, however, referred to as the Alternative Operating Condition (AOC) rule, has been approved into the SIP despite its violating federal law.

- **Breakdowns:** SCAQMD’s breakdown provision makes certain air pollution control rules “inapplicable to a violation directly caused by a breakdown” providing certain criteria are met.¹⁹

Cynthia Babich, Los Angeles, CA

“Choke, choke, gasp, gasp, these upset emissions, which are unreported and unpermitted, gas our community constantly. When we reviewed their Title V permits last year, we found that Exxon Mobil had operated without their electrostatic precipitator working properly for months and that tons of catalyst had been blown out of the catalytic cracking unit into the community. Something needs to be done!”

To qualify for the exemption, a source must demonstrate the following: (1) reporting requirements were met, (2) the breakdown was not caused by operator error, neglect, or improper operation or maintenance procedures, (3) steps were immediately taken to correct the conditions leading to the breakdown and emissions were mitigated to the maximum extent feasible, and (4) the equipment in violation was shut down within 24 hours or at the end of the operating cycle, whichever occurs first.²⁰ As noted above, this rule had not been approved by EPA into the SCAQMD SIP and cannot apply to prevent EPA or citizen enforcement for violations of federal emission standards. It still, however, appears to violate the Clean Air Act requirement that states enforce emission limits at least as stringent as those in the state SIP, as well as the requirement that states have the authority to collect penalties for every violation of the Act.²¹

- *Variances:* The SCAQMD's Hearing Board grants several different types of variances. These include emergency variances, regular variances, and "alternative operating conditions." If the Hearing Board grants a variance, a source is authorized to continue operating in violation of the law.

Rule 517 allows emergency variances for excess emissions lasting less than 24 hours caused by breakdowns. Rule 517 is not approved into the SCAQMD SIP. Variances granted pursuant to rule 517 that authorize violations of federal rules or SIP standards, however, appear to violate Clean Air Act section 116.²²

Rule 518.2 creates an exemption process that allows major sources to exceed their emission limits by changing those limits in their Title V permits. This exemption process is illegal,

but has been approved by EPA into the SCAQMD SIP. The AOC variance is included in SCAQMD's Title V rules and allows facilities to illegally change applicable requirements through their Title V permits. The AOC provision violates numerous requirements of the Clean Air Act and EPA guidance, including the following:

- Clean Air Act (CAA) §502 because Title V permits are not allowed to revise applicable requirements;²³
- CAA §110 because any revisions to the SIP must be approved by EPA and the AOC provision allows revisions to take effect if EPA takes no action;
- CAA §116 because, by granting any variance from SIP limits or other federal standards, SCAQMD is not enforcing emission limits at least as stringent as those in the SIP and federal regulations; and
- EPA's Guidance because the AOC can excuse violations that are not caused by unforeseen or unavoidable circumstances and creates an exemption, rather than an affirmative defense, that applies to both penalties and injunctive relief.

To date, apparently only one facility has applied to SCAQMD for an AOC, and that application is still pending. While the AOC does provide some protections not included in other exemption provisions—such as the requirement for obtaining emission reduction credits or mitigation—it is still an illegal exemption from federal Clean Air Act requirements and should be removed from the SCAQMD SIP.

Reporting: There is no uniform system for reporting excess emissions in SCAQMD. Like BAAQMD, SCAQMD has several reporting requirements that may include some information on upset emissions.

- **Breakdowns:** Facility operators must report breakdowns within one hour of the time they should have known about the violation caused by the breakdown.²⁴ The initial report must include the time, location, equipment, responsible party, and, to the extent known, the cause and estimated time for repairs.²⁵ Within seven days after the breakdown has been corrected, and no later than 30-days after the breakdown, the operator must file a written report, which includes the equipment causing the breakdown; the duration; the date of correction and demonstration of compliance; the identification of the times of emissions, quantification of emissions and basis used to quantify; information demonstrating that the breakdown was not the result of operator error, neglect, or improper operation or maintenance; information substantiating the steps immediately taken to minimize emissions; and a description of the steps taken to avoid similar malfunctions in the future.²⁶
- **Variances:** Petitions for variances are supposed to include an estimate of emissions.²⁷ In addition, the “Calculation of Excess Emission Fees” form that facilities are required to submit should include estimates of emissions.
- **Flaring:** SCAQMD Rule 1118 requires facilities to submit quarterly flaring reports that include the daily and quarterly emissions of criteria pollutants from each flare. The flare monitoring reports should include emissions from

flares resulting from upsets, as well as other causes.

Despite these reporting requirements, it was difficult to gather upset data from SCAQMD. While there is a requirement that breakdown reports include emissions estimates, many of the reports merely stated that emissions were greater than the regulatory threshold or included no information quantifying emissions. Likewise, although the Hearing Board variance records were supposed to include emissions estimates, many of the files did not. Because SCAQMD lacks a centralized reporting system for excess emissions, and because many of the reports we reviewed did not quantify emissions, we could not adequately evaluate the excess emissions from the five SCAQMD facilities studied.

Data: We reviewed breakdown and variance files for the following facilities:

Facility Name	Facility Location
Exxon Mobil	Torrance, CA
Chevron Texaco	El Segundo, CA
BP Amoco	Carson, CA
Conoco Phillips	Wilmington, CA
Conoco Phillips	Carson, CA

As can be seen from the attached spreadsheets, data regarding these facilities' upset emissions were often incomplete.²⁸ Because these reports did not give us a complete picture of excess emission from the facilities, we have not totaled emissions.

NOTES

- ¹ Environmental Working Group, "Still Above the Law: How California's Major Air Polluters Get Away With It" (July 29, 2004).
- ² The rules are not clearly written and could be subject to different interpretation. The interpretation included here is consistent with BAAQMD's stated interpretation.
- ³ BAAQMD Reg. 1-208.
- ⁴ *Id.*
- ⁵ BAAQMD Regs. 1-112 & 1-113.
- ⁶ *Id.*
- ⁷ Ca. Health & Safety Code §42352.
- ⁸ Clean Air Act §116.
- ⁹ BAAQMD Reg. 1-431.
- ¹⁰ BAAQMD Reg. 1-432.
- ¹¹ Hearing Board Rules Section 2.2d.
- ¹² BAAQMD Reg. 12-11-500.
- ¹³ BAAQMD Reg. 8-28-401.
- ¹⁴ 42 U.S.C. §114(a) & (c); 40 C.F.R. §2.301(a)(2)(i).
- ¹⁵ In commenting on a draft of this appendix, BAAQMD stated that its policy is that investigation reports should be available to the public upon request. If the investigation report is part of a notice of violation report, BAAQMD said it should be available in its entirety upon closure of the case.
- ¹⁶ <http://www.baaqmd.gov/enf/incidents/index.asp>.
- ¹⁷ Information on the BAAQMD spreadsheets included in the "Type of Event" column indicates the follow up taken by BAAQMD. NOV means a Notice of Violation was issued. BRG means breakdown relief was granted and NACT means no action taken. In addition, monitor outages are included separately at the end of the BAAQMD spreadsheets.
- ¹⁸ Communities for a Better Environment, "Refinery Flaring in the Neighborhood" (Spring 2004).
- ¹⁹ SCAQMD Rule 430(b)(3).
- ²⁰ *Id.*
- ²¹ Clean Air Act §§116 & 502(b).
- ²² SCAQMD Rule 504 does provide that variances may not be granted from NSPS or NESHAP standards.
- ²³ As EPA stated in its Notice of Deficiency for Indiana's Title V program, "Indiana's rule ... allows the state to address emission limit exceedances for startups, shutdowns, and malfunctions on a case-by-case basis in title V permits. This allows the permitting authority to establish through the title V permitting process limits which exceed applicable requirements. Because Title V does not give permitting authorities the authority to establish new emission limits, Indiana's program does not meet the program approval requirements of title V..." 66 Fed. Reg. 64039, 64040 (Dec. 11, 2001).
- ²⁴ SCAQMD Rule 430(b).
- ²⁵ *Id.*
- ²⁶ *Id.*
- ²⁷ SCAQMD rules 517 & 518.2 and Ca. Health & Safety Code §§42352 & 42353.
- ²⁸ The information on the SCAQMD spreadsheets included in the "Type of Event" column sometimes indicates the determination made, or follow-up action taken by SCAQMD. NOV means a Notice of Violation was issued.

SHELL MARTINEZ REFINERY BAAQMD • Martinez, CA
Emissions Data (Lbs./Event unless noted): 1.01.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/5/02	#3 Sulfur Recovery Plant			16.0	>250 ppm/ hr								Malfunction
12/5/02	Steam Coil in Sulfur Pit												Excess Emission, Breakdown (NOV)
10/12/02	Cat Feed Hydrotreater & Cat cracker	PSV - Noo2		0.0		8			110				Malfunction
9/30/02	Effluent Treatment Plant												Excess Emission (NOV)
9/21/02	#7 Pond			1.0		60 ppb 3 min avg., 118 ppb peak; 35 ppb avg/hr, 118 ppb peak							Malfunction
9/21/02	No Source ID												Excess Emission (NACT)
9/20/02	Sour Water Stripper #7												Excess Emission, Breakdown (NOV)
9/1/02	#3 Hydrogen Plant SMR Furnace			3.0				22 ppm @3% O ₂ /3 hr. avg					Malfunction
8/3/02	LOP Flare												Excess Emission (NOV)
7/20/02	#1 CO Boiler	#1 CO Boiler Stack	>30% <3min/hr	0.1									Excess Emission, Breakdown (NACT)
7/18/02													Excess Emission (NOV)
7/9/02	CCU Gas redistributor												Excess Emission (NOV)
7/4/02	HC Flare			0.1		141 ppm							Excess Emission (NOV)
7/2/02	DMDS Pump	Tubing											Excess Emission, Breakdown (BRG)
6/25/02	DEA Treatment System												Excess Emission (NOV)
6/25/02	SRU ₃												Excess Emission (NOV)
6/25/02	Dea Treatment System												Excess Emission (NOV)

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
6/25/02	DEA Treatment System												Excess Emission (NOV)
6/15/02	Fuel Gas DEA Treater			3.0		165ppm avg							Excess Emission (NOV, NACT)
6/8/02	Analyzer	Flame											
5/31/02	#2 CO Boiler	#2 CO Boiler Stack		0.7			500 - 600 ppm						Excess Emission (NACT)
5/25/02	Feed Heater			11.6				>10 ppm					Excess Emission (NOV)
5/10/02	#3 CO Boiler	#3 CO Boiler Stack		1.0			588 ppm average						Excess Emission (NACT)
5/9/02	#3 CO Boiler	#3 CO Boiler Stack		3.9			>500 ppm						Excess Emission (NOV)
5/8/02	#6 Pond (probably)			1.2		31 ppb 60 min avg/42 ppb peak							Excess Emission (NACT)
5/7/02	#3 Sulfur Recovery Plant			3.0	>500ppm								Excess Emission (NOV)
5/7/02	#6 Pond (probably)			0.7		31ppb 60 min avg/44 ppb peak							Excess Emission (NACT)
4/23/02	#3 Sulfur Recovery Plant	Catalytic Oxidizer		3.0	>250 ppm								Excess Emission (NOV)
4/19/02	#3 Sulfur Recovery Plant	MDEA System		1.0	>250 ppm								Excess Emission (NOV)
4/13/02	?			0.0									Excess Emission (NACT)
4/12/02	#2 CO Boiler	#2 CO Boiler Stack		1.0			591 ppm						Excess Emission (NACT)
4/1/02	#1 CO Boiler	#1 CO Boiler Stack	>20%	2.0			423 ppm; 523 ppm						Excess Emission, Breakdown (NACT)
3/28/02	Pressure relief device - E396	OPCen - Lean oil sponge chiller		0.0					190				Pressure (NACT)
3/12/02	O ₂ Analyzer	Calibration											
3/12/02	Analyzer	Calibration											
3/11/02	Analyzer Hiway	Power Supply											
3/9/02	Analyzer	Calibration											

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOx	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
2/26/02	?												Excess Emission, Breakdown (NACT)
2/26/02	#3 Hydrogen Plant			3.0				10.4 ppm					?
2/20/02	?												Excess Emission, Breakdown
2/14/02	#3 CO Boiler	#3 CO Boiler Stack	≥30%	0.0									Excess Emission (NACT)
1/13/02	OPCen Flare			1.5		>163 ppm		≤192/3hr avg					Excess Emission (NACT)
11/1/01	Vine Hill storage tank vapor recovery system	Pressure relief device - J127		1.2			334lbs; 23 PPMW					natural gas - 440 lbs	Pressure (NACT)
10/18/01	#3 CO Boiler	#3 CO Boiler Stack	≥30%	0.2									Excess Emission (NACT)
10/17/01	#2 CO Boiler	#2 CO Boiler Stack	up to 60% for a maximum of 15min/hr	0.3									Excess Emission (NOV)
10/17/01	#3 CO Boiler	#3 CO Boiler Stack	>60% for a maximum of 14 min/hr	0.3									Excess Emission (NOV)
10/16/01	Pressure relief device - J244	FCC gas plant debutanizer column		0.0			1700 lbs; 1100 PPMW					HC: 950 lbs	Pressure (NOV)
10/14/01	#2 CO Boiler	#2 CO Boiler Stack	up to 60% for a maximum of 41min/hr	2.3									Excessive Emission (NOV)
10/14/01	#3 CO Boiler	#3 CO Boiler Stack	up to 60% for a maximum of 20 min/hr	2.2									Excessive Emission (NOV)
10/12/01	Pressure relief devices - M31 & M36	Fluid Catalytic Cracker		0.1		6.3lbs	5800lbs 1000 PPMW					HC: 7300	Pressure (NOV)
10/12/01	CCU	#3 CO Boiler Stack	>20%	0.7									Excess Emission (NACT)
10/2/01	#3 CO Boiler	Dust hopper	>3min of >Ringleman 1 in an hour	0.1									Excess Emission (NACT)

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
9/30/01	CO boiler	FCC Flue gas emission		19.5		100l	Likely but no monitor					Carbon sulfide - 100; formaldehyde - 100; acetaldehyde - 1000 hydrogen cyanide - 10; ammonia - 100	Breakdown (BRG)
9/18/01	Lube Hydrotreater			0.0		66 ppb							Excess Emission (NOV)
8/28/01	Furfural Unit	Furfural Column											?
8/23/01	Tank 1161			1.2		>30 ppb							Excess Emission (NOV)
8/22/01	Cat Cracker	Pressure relief device - J244		0.1		1 lb						HC: 3200 lbs	Pressure (NACT)
8/9/01	Fuel gas system	Hydrocracker		1.1		169.03 ppm peak							Pressure (NOV)
8/9/01	Fuel gas system	Hydrocracker		2.1		>163ppm							Pressure (NOV)
8/9/01	#3 Hydrogen Plant - 4161	Pressure swing absorption		144.0			54000lb (450 lb/hr for 5dy) = 27tons = more than CO permit/month (26.3)						Excess Emission, Breakdown (BRG)
8/9/01	Pressure relief devices - J231 & J232	Hydrocracker		0.1		17 lbs						HC: 670 lbs	Excess Emission (NOV)
8/9/01	Pressure relief devices - M50 & M53	Hydrocracker		0.1		150 lbs						HC 12000 lbs	Excess Emission (NACT)
7/27/01		Straight Run Hydrotreater		0.0		4.3 lbs						HC: 1500 lbs	Pressure (NOV)
7/18/01	Pressure relief devices - M50 & C82	Naptha Hydrotreater, c-82		0.3		80 lbs						HC: 31,000 lbs	Pressure (NOV)
7/9/01	CFU unit	Fuel Gas Treaters		5.0		163 ppm							Excess Emission (NOV)
7/9/01	CFU unit	Fuel Gas Treaters		6.4		163 ppm							Excess Emission (NOV)
7/2/01	#2 Sulfur Plant			2.0	250 ppm								Excess Emission (NOV)
5/18/01	Fuel Gas System			2.3		164 ppm							Excess Emission (NOV)

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
5/18/01	Fuel Gas System			3.0		192 ppm							Excess Emission (NACT)
5/18/01	#3 hydrogen plant - 4161			0.8				11.2 ppm					Breakdown, Excess Emission (NACT)
4/18/01	#3 Sulfur Recovery Plant			1.0	79 ppm								Excess Emission (NOV)
4/3/01		Catalytic Cracking Unit		2.0			500 ppm						Excess Emission (NOV)
3/19/01	?			0.0		60 ppb							Excess Emission (NOV)
3/5/01	PG&E natural gas header	PRD N-25		0.1								Natural gas: 3680 lbs	Pressure (NACT)
2/7/01	#3 Hydrogen Plant 3 SMR Furnance			3.0				10.7 ppm					Excess Emission (NACT)
2/6/01	#4 Sulfur Recovery Plant			1.0	250 ppm								Excess Emission (NOV)
1/25/01	#3 Sulfur Recovery Plant			1.0	267 ppm								Excess Emission (NOV)
1/16/01	?			0.4		60 ppb							Excess Emission (NOV)

Monitor Outages

12/28/02	Calibrator												Inoperative
12/26/02	Calibrator/Span Drift test Failed												Inoperative
12/20/02	Failed Span Drift Test												Inoperative
12/20/02	Process Analyzer												Inoperative
12/15/02	Calibrator												Inoperative
12/12/02	Low Sample Flow												Inoperative
12/8/02	O ₂ Analyzer												Inoperative
12/7/02	Calibrator												Inoperative
12/5/02	CEMS Sample Cooler Failure												Inoperative
12/4/02	Analyzer												Inoperative
12/3/02	Analyzer												Inoperative
11/28/02	Calibrator												Inoperative
11/27/02	?												Inoperative
11/26/02	Calibrator												Inoperative
11/24/02	Calibrator												Inoperative

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
11/23/02	Analyzer												Inoperative
11/20/02	Calibrator												Inoperative
11/20/02	Calibrator												Inoperative
11/20/02	Data Collection System												Inoperative
11/13/02	Calibrator												Inoperative
11/10/02	Sample Tubing												Inoperative
11/5/02	Calibrator												Inoperative
11/4/02	Electrical												Inoperative
11/3/02	Calibrator												Inoperative
10/30/02	?												Inoperative
10/29/02	Contamination of Stretford Solution												Inoperative
10/27/02	Calibrator												Inoperative
10/22/02	Calibrator												Inoperative
10/22/02	Card Failure												Inoperative
10/13/02	Substation Maint.												Inoperative
10/10/02	Flame out												Inoperative (NOV)
9/24/02	Electrical Power												Inoperative
9/9/02	Sample Line Plugging												Inoperative (NOV)
9/2/02	Calibrator												Inoperative (NOV)
8/31/02	Calibrator												Inoperative
8/31/02													Inoperative
8/30/02	Sample Tube												Inoperative
8/29/02	?												Inoperative
8/21/02	Calibrator												Inoperative
8/12/02	O ₂ Cell												Inoperative
8/9/02	Alternator Switch												Inoperative
8/8/02	?												Inoperative
7/26/02	Calibrator												Inoperative
7/25/02	Calibrator												Inoperative
7/14/02	O ₂ Analyzer												Inoperative
7/13/02	Calibrator												Inoperative

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
7/9/02	Air-Conditioning												Inoperative
7/8/02	Calibrator												Inoperative
7/4/02	Sample Line												Inoperative
7/3/02	Calibrator												Inoperative
7/2/02	Hydrocracker, Dimethyl disulfide spill			0.0		80 ppb 60 min avg/130 ppb peak							Inoperative
7/1/02	Calibrator												Inoperative
6/26/02	Calibrator												Inoperative
6/24/02	Calibrator												Inoperative
6/23/02	Sample System												Inoperative
6/20/02	Analyzer												Inoperative
6/15/02	Analyzer												Inoperative
6/7/02	Calibrator												Inoperative
6/6/02	Pump												Inoperative
5/31/02	Calibrator												Inoperative
5/27/02	Calibrator												Inoperative
5/25/02	Calibrator												Inoperative
5/4/02	Analyzer												Inoperative
5/2/02	Calibrator												Inoperative
4/29/02	Cal Gas Line	Low Flow											Inoperative
4/28/02	Calibrator												Inoperative
4/2/02	Stack O ₂ Analyzer												Inoperative
3/22/02	Analyzer	Calibration Water											Inoperative
3/22/02	Analyzer	Calibration Water											Inoperative
3/22/02	Analyzer	Calibration											Inoperative
3/18/02	Analyzer	Flame											Inoperative
3/5/02	#1 Sulfur Plant			390.5									Inoperative (NOV)
3/5/02	Sample Line	Leak											Inoperative
2/23/02	Analyzer	Electronic Data Collection											Inoperative (NOV)
2/22/02	Sample Line	Plug											Inoperative
2/20/02	Analyzer	Calibration											Inoperative
2/15/02	Calibrator												Inoperative

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOx	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
2/4/02	Motor												Inoperative
1/29/02	Solenoid Valve												Inoperative
1/21/02	Cal Gas Regulator												Inoperative
1/20/02	Calibrator												Inoperative
1/9/02	Analyzer Pump												Inoperative
1/9/02	Sample System												Inoperative
1/6/02	Analyzer												Inoperative
1/6/02	Analyzer												Inoperative
1/6/02	Analyzer												Inoperative
1/5/02	Analyzer												Inoperative
12/31/01	Analyzer												Inoperative
12/31/01	Analyzer	Flame											Inoperative
12/25/01	Analyzer												Inoperative
12/25/01	Analyzer												Inoperative
12/22/01	Analyzer												Inoperative
12/17/01	Nox Analyzer												Inoperative
12/15/01	Vacuum Pump												Inoperative
12/13/01	Detector and Valve												Inoperative
11/28/01	Analyzer	Flame											Inoperative
11/23/01	Calibrator												Inoperative
11/21/01	Calibrator												Inoperative
11/16/01	Control Air Conditioner												Inoperative
11/12/01	Sample Pump												Inoperative
11/12/01	Sample Inlet Line												Inoperative
11/12/01	Analyzer Span												Inoperative
11/2/01	Calibration Failure												Inoperative
10/30/01	Analyzer												Inoperative
10/26/01	Sample Lines												Inoperative
10/26/01	Analyzer												Inoperative
10/21/01	Cal Gas Line												Inoperative
10/20/01	Flow Meter												Inoperative
10/20/01	Sample Conditioning	Bad Solenoid Valve											Inoperative

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
10/18/01	Sample Line												Inoperative
10/16/01		Sample Flow Rate											Inoperative
10/7/01	Flow Meter												Inoperative
10/7/01	Analyzer												Inoperative
10/2/01	Sample Fliter												Inoperative
9/18/01	Electronics												Inoperative
9/10/01	Maintenance												Inoperative
9/1/01	Analyzer												Inoperative
8/30/01	Analyzer												Inoperative
8/28/01	Sample Chiller												Inoperative
8/28/01	Analyzer												Inoperative
8/28/01	Analyzer												Inoperative
8/22/01	Analyzer												Inoperative
8/12/01	Analyzer												Inoperative
8/9/01	Analyzer												Inoperative
8/7/01	Analyzer												Inoperative
8/3/01	Analyzer												Inoperative
8/2/01	Analyzer												Inoperative
7/29/01	Analyzer												Inoperative
7/27/01		Analyzer											Inoperative
7/19/01	Analyzer												Inoperative
7/16/01	Analyzer												Inoperative
7/5/01	#4 EMSR ₁ Boiler			478.5				?					Inoperative (VOID)
6/29/01	Analyzer												Inoperative
6/28/01	Sample System												Inoperative
6/27/01	Analyzer												Inoperative
6/16/01	Analyzer												Inoperative
6/16/01	Analyzer												Inoperative
6/13/01	Analyzer												Inoperative (NACT)
6/13/01	Analyzer			Not Specified									Inoperative
6/11/01	Analyzer												Inoperative

Shell Martinez Refinery BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NO _x	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
6/3/01	Analyzer												Inoperative
5/28/01	Analyzer												Inoperative
5/26/01	Analyzer			2.0				?					Inoperative (NACT)
5/23/01	Analyzer												Inoperative
5/21/01	Analyzer												Inoperative
5/15/01	#4 Sulfur Recovery Unit			139.0	?								Inoperative (NOV)
5/8/01	Analyzer												Inoperative
5/6/01	Analyzer												Inoperative
4/15/01	Fliexigas H2S analyzer			1.0		Excess							Inoperative
3/26/01	Monitor												Inoperative
3/24/01	Analyzer												Inoperative
3/18/01	Monitor												Inoperative
3/17/01	Monitor												Inoperative
3/4/01	Analyzer												Inoperative
2/26/01	Analyzer												Inoperative
2/11/01	Analyzer												Inoperative
2/3/01	Electric data capture system			41.0								Flow	Inoperative (NOV)
1/27/01	o2 cell			0.0									Inoperative
1/15/01	Inoperative parametric			225.6								Flow	Inoperative (NOV)
1/12/01	Electric data capture system			75.0									Inoperative (NOV)
1/7/01	Analyzer												Inoperative
1/4/01	Sample System												Inoperative

TESORO BAAQMD • Martinez, CA
Emission Data (Lbs./Event unless otherwise noted): 1.01.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/30/02	SRU												Excess Emission (NOV, NACT)
12/23/02	Facilitywide												Excess Emission (NACT)
12/18/02	Firebox Burner												Excess Emission (NOV)
10/31/02	Pulsation Dampner												Excess Emission (NOV)
10/27/02	O ₂ Enrichment Valve												Excess Emission (NOV)
10/19/02	?												Pressure (NACT)
10/18/02	Furnace 17			3.0		>160 ppm							Excess Emission (NOV)
9/26/02	Central Deck												Breakdwon (NACT)
9/26/02	ESP Dampner												Excess Emission (NACT)
9/12/02	Air Blower												Excess Emission (NOV), Pressure (NACT)
8/23/02	?												Excess Emission (NOV)
8/9/02	Under Investigation												Excess Emission (NOV)
7/29/02	Electro Static Precipitator												Excess Emission (NACT)
7/26/02	SRU	Dea pump		2.0	405 ppm								Excess Emission (NOV, BRG), Breakdown (BRG),
5/23/02	Facilitywide												Excess Emission, Breakdown (NACT)
5/22/02	Pan												Breakdown (NOV)
4/10/02	Control Module												Excess Emission, Breakdown (NACT)
4/8/02	Substation												Excess Emission (NACT)
4/5/02	By-pass Controller												Excess Emission (NACT)

Tesoro BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
3/13/02	#5 Boilerhouse		>20%	10.3									Excess Emission (NACT, NOV)
3/10/02	Under Investigation												Excess Emission (NACT)
2/27/02	Coker Sluice Tank		>20%	0.3									Breakdown (NACT)
2/26/02	Cold Coke Riser												Breakdown (NOV)
2/22/02	SRU			1.0	269.5 ppm								Excess Emission (NACT)
1/20/02	Facilitywide			0.8		>60 ppb							Excess Emission (NACT)
1/13/02	SRU			1.5	>250 ppm								Excess Emission (NOV)
1/5/02	Fuel Gas Mixpot			3.8		>160 ppm							Excess Emission (NACT)
1/4/02	Unknown			1.0		>30 ppb							Excess Emission (NOV)
1/2/02	Waterfront	Tank farm tract		0.0		62 ppb avg.; 84 ppb peak							Excess Emission (NACT)
12/28/01	#6 Boilerhouse		>20%	16.7									Excess Emission (NOV)
12/28/01	Facilitywide			24.0				.050 lb/MMBTU/day avg.					Facilitywide NOx Bubble Limit, Excess Emission (NACT)
12/24/01	R135												Breakdown (NACT)
12/21/01	Boiler S-1469												Excess (NACT)
12/21/01	No Known Problem			0.0		>60 ppb							Excess Emission (NOV)
12/17/01	Package Boiler												Excess (NACT)
12/15/01	SRU			3.0	>250 ppm								Excess Emission (NOV)
12/13/01	Transformers												Excess Emission (BRG)
12/12/01	Facilitywide												Excess Emission (NACT)
12/11/01	Facilitywide												Excess Emission (NACT)
12/11/01	Leaking condenser			4.4	>50 ppb								Excess Emission (NOV)

Tesoro BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/10/01	Fuel Gas			24.0	>29 lbs per mmbtu								Malfunction
12/10/01													
12/10/01	#56 Furnance			67.0				>40 ppm					
12/10/01													
12/9/01	#6 Boilerhouse			91.9	>250 ppm								?
12/9/01	SRU			1.0	317 ppm								Excess Emission, Breakdown (BRG)
12/9/01	Facilitywide			24.0				?					Facilitywide NOx Bubble Limit
11/27/01	Secondary Seal - 312			?									Breakdown (NOV)
11/26/01	Under Investigation			0.1		>60 ppb							Excess Emission (NOV)
11/7/01	Turnaround & Feed Out												Excess Emission (NACT)
11/4/01	Turnaround & Feed Out												Excess Emission (NACT)
10/11/01	Under Investigation												Excess Emission (NACT)
9/18/01	Under Investigation												Excess Emission (NACT)
9/18/01	Amonia Recovery												Excess Emission (NACT)
9/18/01	SRU			9.4	430 ppm; 435 ppm; 500 ppm; 461 ppm; 470 ppm								Excess Emission (NOV)
9/15/01	#7 Boilerhouse		>20%	0.9									Excess Emission (NOV)
8/26/01	Facilitywide												Excess Emission (NACT)
7/21/01	SRU												Excess Emission (NACT)
7/19/01	SRU			1.0	360 ppm								Excess Emission (NOV)
7/16/01	Under Investigation												Breakdown (NACT)
7/6/01	Tank - 312			?								hydrocarbon	Breakdown (EMI)

Tesoro BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
7/1/01	SRU			1.0	304 ppm								Excess Emission (NOV)
6/13/01	Analyzer												Inoperative
6/13/01	Compressor												Pressure (VOID)
5/17/01	#1 Feed Prep Water Spray												Excess Emission (NOV)
4/11/01	SRU			1.1	>250 ppm								Excess Emission (NOV)
3/10/01	SRU												Excess Emission (NACT)
2/22/01	Amonia Injection Heater												Excess Emissions, Breakdown (NACT)
2/16/01	?												Excess Emission (NACT)
2/11/01	SRU	Steam system	>50%	2.0	>500 ppm								Excess Emission (NOV)
2/10/01	#5 Boilerhouse		>50%	12.7	>500 ppm								Excess Emission, Breakdown (NOV)
2/8/01	Facilitywide												Excess Emission (NACT)
1/29/01	Facilitywide												Excess Emission (NACT)
1/24/01	Facilitywide												Excess Emission (NACT)
1/23/01	Facilitywide												Excess Emission (NACT)
1/21/01	Facilitywide												Excess Emission (NACT)
1/17/01	Facilitywide												Excess Emission (NACT)
Monitor Outages													
12/21/02	Probe Heater	Common Fault Alarm											Inoperative
12/14/02	Blower												Inoperative
12/10/02	Sample Tank	Under Investigation											Inoperative
12/8/02	Drain Pump												Inoperative
11/3/02	Sample Line												Inoperative
10/29/02		Possible Leak											Inoperative

Tesoro BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
10/28/02	Under Investigation												Inoperative
10/19/02	Chiller Drain												Inoperative
10/14/02	Sample Line												Inoperative
10/3/02	CEM												Inoperative
9/21/02	Calibrator												Inoperative
9/11/02	Calibrator												Inoperative
8/24/02	System												Inoperative
8/23/02	Regulator												Inoperative
6/28/02	Under Investigation												Inoperative
6/21/02	Equipment Repairs												Inoperative
6/19/02	Air Conditioning												Inoperative
5/30/02	Measuring Cell												Inoperative
5/26/02	Sample Lines												Inoperative
4/30/02	CEM												Inoperative
4/5/02	Output Module												Inoperative
3/1/02	System												Inoperative
2/24/02	Unknown												Inoperative
2/20/02	Xmitter												Inoperative (NOV)
12/27/01	Facilitywide			0.0		>60 ppb							Inoperative
11/24/01	Sample Gas Rotometer												Inoperative
10/16/01	Lost Calibration												Inoperative
10/5/01	?												Inoperative
9/17/01	Line												Inoperative
9/1/01	Analyzer												Inoperative
8/28/01	Calibrator	Gas Leak											Inoperative
8/20/01	Monitor												Inoperative
7/30/01	PEN												Inoperative
6/9/01	#6 Boilerhouse		>20%	8.2									Inoperative
6/6/01	CEM												Inoperative
6/2/01	Valve												Inoperative
5/30/01	Ink Pen												Inoperative

Tesoro BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
5/19/01	Source Lamp												Inoperative
5/9/01	Cooler Unit												Inoperative
4/15/01	Instrumentation												Inoperative
4/14/01	Various Components												Inoperative
4/1/01	Sample Line												Inoperative
3/12/01	Switch												Inoperative
3/6/01	Line												Inoperative
2/17/01	O ₂ Analyzer												Inoperative

VALERO BAAQMD • Benicia, CA
Emissions Data (lb./event unless otherwise noted): 1.01.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/19/02		SG-1032 Boiler		1.4			>50 ppm						Breakdown (BRG)
12/19/02	Main stack	FCCU Regenerator	2.5 ppm	0.7									Excess Emission (MIS)/ Breakdown (NACT)
12/4/02	Furnance 4460	Hot Oil Burner		1.8				10.4 ppm					Excess Emission (NACT)
11/20/02	Main stack	FCCU Regenerator	≥30%	1.0									Excess Emission (NACT)
11/9/02	Substation												Excess Emission/ Breakdown (NOV)
11/8/02	?												Excess Emission (NOV)
10/12/02	SCR system	Furnance 4460		0.9				11 ppm					Excess Emission (NACT)
10/11/02	SCR system	Furnance 4460		7.0				15.9 ppm					Excess Emission/ Breakdown (BRG)
10/3/02	Ammonia Vaporizer												Excess Emission/ Breakdown (NOV)
10/1/02	Fuses												Excess Emission/ Breakdown (NOV)
9/28/02	Injection Quill												Excess Emission/ Breakdown (NOV)
9/23/02	Main stack	FCCU Regenerator	≥30%	0.2									Excess Emission (NACT)
6/6/02	Analyzer												Excess Emission/ Breakdown (NOV)/ Inoperative
6/3/02	Flare gas compressor	South Flare	1 Ringlemann	4.7									Excess Emission/ Breakdown (NOV)
6/3/02	Main stack	FCCU Regenerator	2.2 Ringlemann	0.0									Excess Emission/ Breakdown (NOV)
6/3/02	Flare gas compressor	North Flare	1 Ringlemann	4.7									Malfunction
5/30/02	Coker Burner	FCCU Regenerator	≥30%	0.0									Excess Emission/ Breakdown (NACT)
5/21/02	?												Breakdown (NOV)

Valero BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
5/16/02	Coker Burner	FCCU Regenerator	≥30%	0.1									Excess Emission/ Breakdown (NACT)
5/14/02	Coker Burner	FCCU Regenerator	≥20%	0.2									Excess Emission/ Breakdown (NACT)
5/1/02	"B" Cell Rectifiers	main stack	≥30%	3.6									Excess Emission/ Breakdown (NACT)
4/22/02	PR-101BOutlet	FCCU Regenerator	≥30%	0.1									Excess Emission (NACT)
4/16/02	Coker Burner												Excess Emission, Breakdown (NOV) (NACT)
2/25/02	Boiler Feed			0.0									Breakdown (NOV)
2/18/02	Coker Burner	FCCU Regenerator	≥30%	0.0									Excess Emission (NACT)
1/28/02	Analyzer												Excess Emission (NOV), Inoperative
1/7/02	Coker Burner	FCCU Regenerator	≥30%	0.1									Excess Emission (NACT)
1/6/02	?												Excess Emission (NOV)
1/5/02	Coker Burner	FCCU Regenerator	≥30%	0.5									Excess Emission (NACT)
1/4/02	FCCU Regenerator			0.0									Excess Emission (NACT)
1/4/02	Coker Burner	FCCU Regenerator	≥30%	0.2									Excess Emission (NACT)
1/3/02	Boiler												Excess Emission, Breakdown (NOV)
12/18/01	Electrical Short												Excess Emission, Breakdown (NOV)
11/29/01	Asphalt plant fuel gas			0.1		≤12ppm/3 hr. avg.							Process fuel production
10/19/01	Process Gas Turbine	SRC system		2.6				11.1 ppm					Excess Emission (NOV)
9/24/01	Coker Burner	FCCU Regenerator	≥30%	0.1									Breakdown (NACT)
9/19/01	Coker Burner	FCCU Regenerator	≥30%	0.2									Excess Emission (NACT)

Valero BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
9/17/01	Crude Preheat Furnace (F-101)	FCCU dump stack	≥30%	0.2									Breakdown/ Excess Emission (BRG)
9/1/01	Scrubbing system	Fuel Gas		0.7		165.30 ppm							Excess Emission (NACT)
8/27/01	Scrubbing system	Fuel Gas		1.5		178.94 ppm							Excess Emission (NACT)
7/5/01	Amonia Injestion System	Main Stack	≥30%	0.1				?					Excess Emission, Breakdown (NACT)
7/3/01	Process Gas Turbine (GT-702)	Ammonia injection nozzle		1.0				11 ppm/ 1 hour					Excess Emission (NACT)
6/23/01	Boiler & SCR												Excess Emission, Breakdown (BRG)
6/21/01	Process Gas Turbine (GT-702)			122.3				excess greater than 9 ppm/3 hour					
5/20/01	Unknown	Flexsorb Stack		0.0		greater than 60 ppb /3 minutes							Excess Emission (NACT)
5/12/01	Process Gas Turbine (GT-702)	Steam generator (SG-702)		3.0				13.3 ppm					Excess Emission (NOV)
4/20/01	Cat Feed Hydrofiner	MEA Absorber Tower (T-601)		0.0		96 ppb (avg)							Excess Emission/ Breakdown (NOV)
3/26/01	Sulfur Recovery Unit "B"	Flexsorb Stack		0.1		136 ppb (avg)							Excess Emission (NOV)
3/14/01	SRU	Analyzer											Excess Emission, Breakdown (BRG)
2/1/01	LPG	Monitor											Excess Emission (NACT)
1/23/01	?												Excess Emission (NACT)
1/5/01	HCU	Leak											Breakdown (NACT)
1/5/01	HCU	H ₂ Vent											Excess Emission (NACT)
Monitor Outages													
11/27/02	Analyzer												Inoperative
11/26/02	FE-32 Flow Totalizer on Crude Unit												Inoperative

Valero BAAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
9/20/02	CEM												Inoperative
9/17/02	Analyzer												Inoperative
8/30/02	Monitor												Inoperative (NOV)
8/29/02	Analyzer												Inoperative
8/16/02	Analyzer												Inoperative
7/3/02	wvf205 Vapor Flow Meter												Inoperative
4/20/02	Analyzer												Inoperative
12/22/01	O ₂ and CO ₂ Chems failed												Inoperative
12/4/01	Analyzer												Inoperative
11/24/01	Analyzer												Inoperative
11/2/01	Analyzer												Inoperative
10/27/01	Failed Detector												Inoperative
8/12/01		S# 31, 32, 33											Inoperative
7/15/01	Analyzer	Sample Tubing											Inoperative
7/8/01	Analyzer												Inoperative
5/29/01	CO Detector												Inoperative
3/12/01	Sample Lines												Inoperative
2/26/01	Detector												Inoperative
2/25/01	?												Inoperative

**BP WEST COAST PRODUCTS SCAQMD • Carson, CA
EMISSIONS DATA (LBS./EVENT): 1.01.01 – 12.31.02**

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
11/30/02	FCCU ESP			1.5								PM 290	Breakdown
11/26/02	Cogen units			0.7	41.8								Invalid Breakdown (NOV issued)
11/25/02													
11/18/02	NE Tank Farm	Vapor Recovery Sys.		25.0								"negligible emissions"	
10/22/02	Compressor	Flare	excess	0.1	7.0		5,793.0	1,065.0				PM 257; ROG 986	Invalid Breakdown
10/20/02													
09/23/02	ESPs for FCCU		20+									PM 11.9	
09/06/02	CEMS to Turbine												
08/24/02	Coker Plant	Fire & Flare		0.4	14,080.0		14,836.7	3,014.0				ROG 2529.7	
08/12/02	FCC	ESP exhaust stack	85 (smoke)										
03/01/02	Claroil pump at cc unit	Leak											Invalid Breakdown
02/21/02	Loading rack												Breakdown
01/25/02	Coker Frac Swing Tower	Leak											NOV
6/8/01	FCCU Main Air Blower	Fire	smoke									SO ₂ , CO, PM	
06/04/01	Analyzer failure												
05/25/01	FCCU	Flare, ESP	smoke									SO _x	Breakdown
05/07/01	Uacuum Unit fire												
2/4/01	No. 2 Crude Fin Fan	Leak		3.3					56.0				

CHEVRON EL SEGUNDO SCAQMD • El Segundo, CA
Emissions Data (Lbs./Event unless otherwise noted): 1.01.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/7/02													breakdown
11/26/02	Cogen Unit A Train			1.2				over 9ppm					breakdown
11/20/02													
11/8/02	Cogen Unit A Train	Flare										SO ₂ , CO	retrofitting
10/16/02	Compressor Spillback system IP Transducer	Flare		4.0								SO _x , NO _x , H ₂ S	breakdown
10/15/02	K-751 Blower	Incinerator stacks										SO _x & NO _x	breakdown
10/14/02	SRU blower											SO _x , NO _x , H ₂ S	operator error (NOV)
10/13/02													
9/24/02	PRD	Spill										20 barrels crude	breakdown
9/23/02													breakdown
8/26/02	Suflur Plant			20.3	46.5								
8/19/02	Coker Unit												breakdown
6/10/02	Wash pad fire												breakdown
5/30/02	SMR plant												
5/23/02	Tank 209	Spill										3 barrels methanol	breakdown
5/23/02	Ammonia feed pumps lost power												
5/1/02	Alky Plant Debutanizer Reflux Pump											gas leak with over 50,000 ppm/dy	variance denied
4/19/02	CoGen Train C			0.2								CO exceedance	
3/21/02	Compressor plugged line												no violations
2/26/02	Vacuum Resid De-Sulfurization unit	Seal Oil Reservoir										sour H ₂	invalid breakdown; NOV issued
2/20/02	Wet Gas Compressor	FCC Flare	smoke										
2/18/02													breakdown
1/28/02	Boiler Feed Water Pump											no violations	breakdown
1/20/02	VRDS Unit	Fire		3.0	3,413.4	25,375.0		31.3				DEA 457.07, HC 22985	
1/10/02	SNR Furnace											PM11855.5	variance

Chevron El Segundo SCAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/27/01	Cogen B Steam Injection			1.0				23.9					
12/13/01	Fuel gas mixture gas analyzer												breakdown
12/6/01	Heater F201-A at #2 Resid Unit											no excess emissions	breakdown
12/6/01	Cogen B Steam Injection			2.0				19.1					no violation
12/5/01	Heater F201-A at #2 Resid Unit			0.3								no excess emissions	
12/4/01	Cogen A Train and Heater F201A			0.1								no excess emissions	breakdown
12/1/01													breakdown
11/28/01	#2 Resid Unit heater F201A			0.2								no excess emissions	breakdown
11/27/01	#2 Resid Unit heater F201A			0.5								no excess emissions	
11/25/01	Steam Naphtha Reformer											no excess emissions	
11/7/01	Cogen Trains A & C			5.0								no excess emissions b/c limits don't apply during SS	
9/21/01	Boiler 39			0.2				11.6					breakdown
9/11/01	SRU #70 Stack			0.7	285.7								
9/5/01	#2 Resid. Heater F201A			0.1								no excess emissions	shutdown
9/4/01	Strainer on Pump P-22	spill										10-20 barrels crude naphtha	breakdown
8/25/01													invalid Breakdown (operational not mechanical problem)
8/24/01													breakdown
8/15/01	Heater F-201A			3.0				2.3					
7/26/01	Compressor K-302	FCCU Flare		2.8				16.6					
7/15/01													
7/13/01	Heater F-1330							5.6					invalid Breakdown (NOV issued)
7/5/01	SCR serving CoGen Train B			0.3								NOx	breakdown

Chevron El Segundo SCAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
6/27/01	Heater F-201A at #2 Resid Unit											no excess emissions	
6/21/01	SNR furnice											PM:	breakdown
6/19/01	Exchanger E322 at DFH Unit			1.3								no excess emissions	breakdown
6/18/01	Cogen B Train			0.3			0.1						breakdown
6/17/01													invalid breakdown
6/15/01	NH ₃ Injection			0.2				6.3					breakdown
5/16/01	Heater F-201A serving #2 Resid Unit			0.3			1.1						
5/16/01	Heater F210A serving #2 Crude Unit											no excess emissions	breakdown
5/11/01													breakdown
4/17/01	NH ₃ Injection serving #4 Crude Unit heaters			31.0								no excess emissions b/c no NOx limit	
4/14/01													
4/5/01	LSFO Flare, Compressors			0.4	3.6			1.6					breakdown
4/3/01	Basin F6			4.8					2.0				
3/30/01	NH ₃ injection serving heaters at VRDS			0.4								no excess emissions b/c RECLAIM	breakdown
3/28/01												PM: 5214	breakdown
3/27/01	NH ₃ Injection serving #4 Crude Unit heaters			13.0								no excess emissions b/c no NOx limit	breakdown
3/27/01	NH ₃ Injection serving Cogen C Train			0.4								no excess emissions b/c RECLAIM	breakdown
3/24/01													
2/20/01	Compressor K-951			3.1	47.0	0.5		17.6					
2/19/01	NH ₃ Injection serving #4 Crude Unit Heater											no rules violated	breakdown
2/14/01	tank 997	Floating roof		72.0					788.0				variance (breakdown)
2/14/01													
2/13/01	Compressor K-951			4.3	218.4	2.4		18.9					breakdown

Chevron El Segundo SCAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
2/10/01													
2/5/01	NH ₃ injection serving Heater F1330			18.8				324.0					breakdown
1/31/01	Unit 118 heater												breakdown
1/30/01	Incinerator F205 serving SRU 20		exceeded	5.0									breakdown
1/26/01	Compressor K-951			3.3	31.4	0.3		9.9					breakdown
1/22/01	CO Boiler #39			0.3								CO exceedance	invalid breakdown (operational problem)
1/20/01	Cogen C Train			0.4			2.2						invalid breakdown
1/1/01	Compressor K-951								1,791.5				

CONOCO PHILLIPS SCAQMD • Carson, CA
Emissions Data (Lbs./Event): 1.01.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/2/02	Boiler 10												
6/19/02	FCCU												Variance Denied
5/8/02	Sulfur Plant No. 2			120.0	0.5	3.2							Variance (maintenance)
5/6/02	Boiler 10			0.3									
1/9/02	FCCU		60-100									1,400 PM	Variance (startup after turnaround)
11/9/01	Boiler 10 & 11												Breakdown
6/22/01	FCCU		20-60 (as high as 100)	96.0								1,400 PM	Variance (startup after maintenance)
4/25/01	Coker Unit	Cleanup		216.0								unspecified	Variance
4/23/01	Coker Unit	Fire											Breakdown (NOV for H&S 41701 (a))
3/7/01	Vacuum Unit	Valve											Invalid Breakdown (acknowledged poor maintenance, no NOV)
3/3/01	Coker Unit	Fire											
2/8/01	FCCU		40	144.0								1,400 PM	Variance (startup after maintenance)
1/10/01	SRU 2	Valve Failure											Request for Variance
1/19/01	Facility			288.0					604.8				Variance (for additional throughput)
1/9/01	SRU tailgas unit	Flare											Breakdown but still NOV for nuisance

CONOCO PHILLIPS SCAQMD • Wilmington, CA
Emissions Data (Lbs./Event): 1.1.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/12/02	Cogen Unit			0.3								NOx	
11/16/02	Cogen	Flare						12.2					Breakdown
9/8/02													
9/4/02	Transformer	Sulfur Pit Blower											Breakdown
7/16/02	Vent Blower												
3/7/02	Tank vapor recover blowers												
3/7/02	Absorbor tower line at acid plant												
1/8/02	Boiler #6			2.5									
12/12/01													
9/11/01	Sulfur pit blower failure											H2S	Breakdown
8/21/01													
6/21/01	FCC Unit	Flares	smoke										
6/18/01	Precipitator		exceeded									PM	Invalid breakdown (NOV)
3/2/01	Level controller malfunction												
1/31/01													

EXXON MOBIL SCAQMD • Torrance, CA
Emissions Data (Lbs./Event): 1.1.01 – 12.31.02

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
12/29/02													
12/16/02													
12/10/02	Bypass dampers							550.0					Variance (testing)
12/5/02	Vapor recovery system Tank 510x4			144.0	1.0		875.0	161.0				PM 15, 149 NMHC	Breakdown (Variance)
12/4/02	Tanks	Vapor recovery line		3.5					1.0				Breakdown
12/3/02	SCR												
11/28/02	SCR heater 19F-1												
11/25/02													
11/19/02	Pump barring failure	Fire	20+	0.1									Invalid Breakdown
11/16/02													
11/15/02													
11/12/02	Multiple sources			312.0				2,999.1					Variance
11/4/02													
10/29/02		Flare	20+	0.6									Breakdown
10/26/02	2K1 Compressor	Flare		12.3				1,765.0					Breakdown
10/23/02	FCCU blower			0.7								No excess b/c under RECLAIM	Breakdown
10/18/02	Tank 500 x1 chiller	Leak		432.0								Freon 12	Invalid Breakdown (NOV issued)
10/16/02	Coke barn	storage piles		2,160.0								PM10	Variance
9/30/02													
9/27/02													
9/19/02	Coker Unit	Fire & Flare	20+	0.5	722.0	43.0		17.0	11,148.0	45			Breakdown
9/12/02	ESP power failure	Flare	20+	7.0								PM 33.6	Breakdown
9/9/02	Hydrogen unit pressure swing absorber			12.0	3,573.0		2,340.0	430.0				PM 136	Breakdown
9/1/02													
8/29/02	SCR			0.1				309.0					Breakdown
8/15/02	Hydrogen unit pressure swing absorber		20+	22.0									Breakdown
8/6/02	FCCU main air blower		20+	18.0	180.0			800.0				PM 15.1	Breakdown

Exxon Mobil SCAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
8/3/02													
8/2/02	Tank 400x31 valve	Flare		2.8	0.0			3.6					Breakdown
7/3/02	Units 1F1 & 1F2	Units 1F1 & 1F2		2,160.0				32,000.0					Variance denied
6/10/02	Crude Heater 1F-2 bypass vent	Vent		0.4				14.8					?
3/5/02													
2/21/02													
2/19/02	Hydrogen Unit valve	Flare		3.1				61.0					Breakdown
2/11/02													
2/6/02	MHF Alkylation Unit	Leak										Butane	?
2/6/02	FCC Regenerator flange	Leak		6.4								14 tons catalyst	Breakdown
1/24/02													
12/18/01		Vacuum hearing & catalytic hydro-desulfurization unit		5.2				2,999.1					Variance granted
11/30/01													
11/28/01													
11/8/01													
11/6/01	Blower Motor & VFD	Bypass Stacks		18.0				12,600.0				Requ'd obtain RECLAIM credits	Maintenance Variance
10/25/01	Alkylantion Unit	Valve stem lek		288.0				2.4				Possible HF emissions	Variance denied
10/16/01													
10/10/01	Fulfur Plant cooler	Leak		0.4		1.6							Breakdown
10/6/01													
10/5/01													
8/2/01	Hydrotreater Fractionator Tower	Heaters		456.0				89.3				Excess emissions were offset at facility	Maintenance Variance
7/3/01													
6/29/01													
6/23/01	Power bumps - sour water stripper, compressor, SCRs, CO boiler	Flaring										NOx & SOx	Breakdown

Exxon Mobil SCAQMD, continued

Start Date	Unit	Emission Point	Opacity (%)	Duration (hrs.)	SO ₂	H ₂ S	CO	NOX	Total VOCs	Benzene Compounds	Butadiene	Other Emissions	Type of Event
6/10/01													
5/17/01													
4/26/01													
4/12/01	Hydrocracker unit compressor	Leak	20+										Breakdown
4/4/01	SRU Fuel Gas Regulator											No excess emissions	Breakdown
3/28/01	Thermal oxidizer												Invalid breakdown (NOV)
3/13/01													
3/6/01	SRU sulfur CEMS												Not a breakdown
2/18/01													
2/13/01	FCCU CO boiler fan	Boiler stack	20+										Breakdown
2/8/01	Alkylation Unit	Leak							2,500.0				Breakdown
2/7/01													
2/5/01	Incinerators serving wastewater separators			0.4					8.0				Breakdown
2/4/01													
2/3/01													
2/2/01													
1/31/01													
1/29/01													
1/28/01													
1/20/01													
1/17/01													
1/15/01													
1/13/01													
1/5/01													